



Basic wiring diagram DOD

Wiring proposal DOD
with nighttime reduction
and defrost inhibition

Daytime operation:

- Raise of set-point value by 5k
- No defrost
- Contact U1 13-14 closed
and U1 23-24 closed

Nighttime operation:

- Set-point value = room temperature
- Defrost processes possible
- Contact U1 13-14 open
and U1 23-24 open